



London Underground
Infrastructure Protection

3rd Floor
Albany House
55 Broadway
London SW1H 0BD

Your ref: 18/AP/1604
Our ref: 24211-SI-J012

Michael Glasgow
Development Management
Michael.glasgow@southwark.gov.uk

22 June 2018

Dear Michael,

Canada Water Masterplan Roberts Close London SE16

Thank you for your communication of 18th June 2018.

Though we have no objection in principle to the above planning application there are a number of potential constraints on the redevelopment of a site situated close to underground tunnels and infrastructure. Therefore, it will need to be demonstrated to the satisfaction of LUL engineers that:

- the development will not have any detrimental effect on our tunnels and structures either in the short or long term
- the design must be such that the loading imposed on our tunnels or structures is not increased or removed
- we offer no right of support to the development or land

Therefore we request that the grant of planning permission be subject to conditions to secure the following:

The development hereby permitted shall not be commenced until detailed design and method statements (in consultation with London Underground) for each stage of the development affecting London Underground assets for demolition, foundations, basement and ground floor structures, or for any other structures below ground level, including piling (temporary and permanent), have been submitted to and approved in writing by the local planning authority which:

- provide details on all structures
- provide details on the use of tall plant/scaffolding
- accommodate the location of the existing London Underground structures and tunnels
- accommodate ground movement arising from the construction thereof
- and mitigate the effects of noise and vibration arising from the adjoining operations within the structures and tunnels.

London Underground Limited
trading as London Underground
whose registered office is
55 Broadway
London SW1H 0BD

Registered in England and Wales
Company number 1900907

VAT number 238 7244 46

London Underground Limited is
a company controlled by a local
authority within the meaning of
Part V Local Government and
Housing Act 1989. The controlling
authority is Transport for London.

The development shall thereafter be carried out in all respects in accordance with the approved design and method statements, and all structures and works comprised within the development hereby permitted which are required by the approved design statements in order to procure the matters mentioned in paragraphs of this condition shall be completed, in their entirety, before any part of the building hereby permitted is occupied.

Reason: To ensure that the development does not impact on existing London Underground transport infrastructure, in accordance with London Plan 2015 Table 6.1, draft London Plan policy T3 and 'Land for Industry and Transport' Supplementary Planning Guidance 2012.

We also ask that the following informative is added:

The applicant is advised to contact London Underground Infrastructure Protection in advance of preparation of final design and associated method statements, in particular with regard to: demolition; excavation; construction methods; tall plant and scaffolding

If I can be of further assistance, please contact me.

Yours sincerely

Shahina Inayathusein

Information Manager

Email: locationenquiries@tube.tfl.gov.uk

Direct line: 020 3054 1365